

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 150

Dated: 29/02/2024

FIRE SAFETY CERTIFICATE

Certified that the **K.R. Mangalam World School** located at S-Block, Greater Kailash-II, New Delhi-110048 comprised of basement, ground plus 04 upper floors owned/occupied by K.R. Mangalam World School, was issued FSC by this department vide letter No F6/DFS/MS/School/2020/SZ/32 dated 30/01/2020 for ground plus three upper floors only. The premise was re-inspection by officer concerned by this department on 20/02/2024 in the presence of Mr. Pratyush Kumar Singh (JE/Bldg/Civil) and observed that there is addition of 4th floor in the existing Basement, ground plus 03 floors building. Now the school **building is comprised of basement, ground and 04 upper floors**, have complied with the fire prevention and fire safety requirements in accordance with rules 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Educational, Group-B" (School)** as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29 / 02 / 2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) Department, Civic Center, Minto Road, New Delhi 110002 (Online ID 10087543 dated 16-02-2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.